



Paul R. LePage  
GOVERNOR

STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0016

David Bernhardt  
COMMISSIONER

April 11, 2016  
Subject: Bridge Painting  
State WIN: 016854.00, 016873.00,  
018937.00, 018938.00 & 018940.00  
Location: **Brunswick & Topsham**  
**Amendment No. 1**

Dear Sir/Ms:

The following question has been received:

Question: Is suspended platform allowed on this project, and what is the minimum clearance allowed?

Response: A suspended platform is allowed beyond the limits of the two 14' travel lanes required in the 105 Special Provision.

Question: Is work allowed on the platform over traffic?

Response: No suspended platforms or work is allowed over traffic.

Question: Proposal ID 016854.00 requires "Temporary Sound Walls" Special Provision 652, bid Item No. 652.55. I see the height requirement, but I do not see a length (ln ft) requirement. The bid item is lump sum. What is the number of feet required for each bridge?

Response: The Sound wall is designed by the contractor to meet the requirements of Special Provisions 652 High Noise, and 652 Sound Attenuation Wall. The length of the wall is determined by the contractors design.

Consider this change and information prior to submitting your bid on **April 13, 2016**

Sincerely,

George M. A. Macdougall P.E.  
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER